

**F17** JOIST TO DROPPED BEAM CONNECTION, STEP DOWN

$\frac{23}{32}$ " 48/24 APA Rated  
Sheathing or onCENTER  
rim board

8d nails

APA Rated Sheathing  
or Sturd-I-Floor

Hanger

onCENTER LVL  
or glulam beam

Bearing stiffeners may be  
required at hangers (see  
detail F18).

See detail F7 for braced wall blocking requirements.